

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0476:141 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Harrington Signal Inc., 2579 4th Ave., Moline, IL 61265
Contact: Andrew Keller (309) 762-0731

DESIGN: Strobe Models SSTG024V15WR*, SSTG024V15WW, SSTG024V30WR, SSTG024V30WW, SSTG024V15/75WR, SSTG024V15/75WW, SSTG024V15/75CR, SSTG024V15/75CW, SSTG024V15/75WRS, SSTG024V15/75WWS, SSTG024V30/75WR, SSTG024V30/75WW*, SSTG024V60WR, SSTG024V60WW, SSTG024V110WR, SSTG024V110WW, SSTG0120VAC177WR, SSTG0120VAC177WW, SSTG0120VAC177CR, and SSTG0120VAC177CW. All units may be followed by suffix -C or -W (ceiling or wall mount) and -W or -R (white or red). Models with suffix -Z are synchronized strobe and are intended for connection with the sync module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Candela: -15: 15cd; -15/75: 15cd & 75cd at 0° angle axis
-30/75: 30cd & 75cd at 0° angle axis; -30: 30cd; -60: 60cd
-110: 110cd; -177: 177cd
Electrical: -120: 120 VAC; -4: 21-30 VDC; -2: 10-16 VDC
Flash Rate: 60 flashes per minute

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and candela ratings and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. For indoor use only.

NOTE: Formerly 7300-0569:114

XLF: 7135-0569:114

*Corrected 10-13-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 9, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager